




The State of New Hampshire  
**Department of Environmental Services**



Michael P. Nolin  
Commissioner

April 11, 2005

Mr. David R. Hazelwood  
Rindge Memorial School  
45 School Street  
Rindge, New Hampshire 03461-9568

**CERTIFIED MAIL (7099 3400 0018 1290 2483)**  
**RETURN RECEIPT REQUESTED**  
**LETTER OF DEFICIENCY**  
**No. ARD 2005-006**

**RE: The Rindge Memorial School**

Dear Mr. Hazelwood:

On December 22, 2004, personnel from the New Hampshire Department of Environmental Services, Air Resources Division ("DES"), conducted an inspection for compliance with the Asbestos Hazard Emergency Response Act of 1986 ("AHERA"), 15 USC Section 2641 *et seq.*, and the regulations promulgated pursuant to AHERA, 40 Code of Federal Regulations ("CFR") Part 763 Subpart E – *Asbestos Containing Materials in Schools*, at the Rindge Memorial School, Rindge, NH (the "School").

During the inspection, DES personnel met with School officials, discussed the objectives of the inspection, and provided School officials with copies of the United States Environmental Protection Agency ("EPA") form 7740-1 *Receipt for Samples and Documents* and EPA form 7740-3 *Notice of Inspection*. During the inspection, DES personnel reviewed facility records and documentation and provided information about AHERA.

As a result of the inspection and information gathered, this Letter of Deficiency ("LOD") is being sent to identify the following deficiencies:

1. The School failed to conduct a re-inspection every 3 years after a management plan was implemented, as required by 40 C.F.R. § 763.85(b)(1).
2. The School failed to conduct periodic surveillance in each building that it leases or owns that contains asbestos-containing building material ("ACBM") (or assumed) every 6 months, as required by 40 C.F.R. § 763.92(b)(1).

DES believes that these deficiencies can be resolved by the School taking the following action:

3. The School shall conduct a re-inspection every 3 years after a management plan is implemented, as stipulated in 40 C.F.R. Section 763.85(b)(1).
4. The School shall conduct periodic surveillance in each building that it leases or owns that contains ACBM (or assumed) every 6 months, as stipulated in 40 C.F.R. Section 763.92(b)(1).

Within thirty (30) days of issuance of this LOD, the School must submit a written, signed statement specifically describing the actions the School has taken to address the findings cited above, and to preclude further violations of the AHERA regulations.


Please address all information to Marjorie Yin, at the following address:

NHDES Air Resources Division  
Compliance Bureau  
P.O. Box 95  
Concord, NH 03302-0095

Please be advised that DES will continue to monitor the School's compliance status and that this letter does not provide relief against any other existing or future deficiencies. A copy of this LOD and any documentation of the corrective action received from the School will be provided to the EPA. Compliance with this LOD does not preclude the EPA from pursuing any other remedies or sanctions authorized by law. Such sanctions may include administrative, civil, and/or criminal action, which may be available by reason of the failure of the School, its officers, employees, or agents to comply with AHERA or the regulations promulgated under AHERA.

If you believe that DES has cited these deficiencies in error or if you have any questions or require additional information regarding this matter, please contact Mr. Steve Cullinane, Asbestos Program Manager, Compliance Bureau, Air Resources Division, at (603) 271-1373 or Marjorie Yin, Compliance Bureau, Air Resources Division, at (603) 271-4555.

Sincerely,

  
Pamela G. Monroe  
Compliance Bureau Administrator  
Air Resources Division

PGM/jwr

cc: W. Toland, EPA Region 1  
G. Hamel, Legal Unit Administrator  
AFS # 3300085555